



Value Engineered **QUARTER TURN BALL VALVES**

Material Specifications

- Value engineered and nickel plated
- Working pressure: 20psi-125psi with intermittent impulse up to 180ps
- Operating temperature: 40°F-160°F with intermittent temperatures up to 180°F
- O-Rings/Washers NSF/ANSI 61 compliant chlorine/chloramine resistant NBR or EPDM

Design Features

- · Quick & easy quarter turn shut off
- Value engineered nickel plated brass ensures durability at optimized value
- · Ball style valve will not freeze up
- PTFE seats for extra wear resistance
- · Chloramine/chlorine resistant o-rings will not break down due to oxidation
- 3/8" compression nut & ferrule sold separately if needed (P-06706)
- One year limited warranty
- · Innovative connection designed to eliminate additional leak paths



Compliance/Listings

- IAPMO listed Lead Free Compliant File No. 6545
- IAPMO listed to NSF/ANSI 61 File No. N-6614
- IAPMO listed to ASME A112.18.1/CSA B125.1 File No. 4577

ASME A112.18.1/CSA B125.1





ACCESSORIES

| P/N | DESCRIPTION | BAG QTY | CARTON QTY |
|---------|--|--------------------------------------|---------------------------------------|
| P-06706 | Bag of 30 3/8" OD Comp Nut and Ferrules | *1 Bag of 30 Nuts and Ferrules | 10 Bags of 30 Nuts and Ferrules |
| P-06735 | Tee adapter, Female 3/8" Comp x 2 x Male 3/8" Comp | N/A | 100 pcs |

*Order for 1 piece of P-06706 = 1 Bag containing Compression Nuts and Ferrules

| ANGLE VALVE P/N | STRAIGHT VALVE P/N | INLET | OUTLET | BAG QTY | CARTON QTY |
|-----------------|-----------------------|------------------|------------------|------------|---------------|
| VE-101-A-LL | VE-101-S-LL | 5/8" O.D. COMPR. | 3/8" O.D. COMPR. | 30 | 180 |
| VE-103-A-LL | VE-103-S-LL | 1/2" CRIMP PEX | 3/8" O.D. COMPR. | 30 | 180 |
| VE-104-A-LL | VE-104-S-LL | 1/2" UPONOR PEX | 3/8" O.D. COMPR. | 30 | 180 |
| VE-500-A-LL | - | 1/2" CPVC | 3/8" O.D. COMPR. | 30 | 180 |

*Bag Quantities = Order Multiples

| Product Submittal | | | | |
|-------------------|-----------|--|--|--|
| Job Name: | Date: | | | |
| Part Number: | Quantity: | | | |
| Architect: | | | | |
| Contractor: | | | | |

Content matter is subject to change at any time. It is the user's responsibility to ensure the most updated revisions are obtained. Rev A 04/2021